



**Technical Decision No.tc2-12-01**

**August 2012**

**ADDITIONS BY WAY OF TECHNICAL DECISION TO ET 101: 2008**

***Page 73: Section 513.1 General:*** Addition:

In commercial, industrial and similar installations where distribution boards (switchgear assemblies) are installed artificial lighting shall be provided to give an adequate degree of illumination to ensure that persons can work safely during the operation or maintenance of the electrical equipment. See also Section 539.

***Page 116: Section 539.3 Switch rooms:*** Addition:

f) Adequate lighting shall be provided in switch rooms in accordance with the Section 513.1. In addition, emergency lighting shall be provided which shall be designed, installed and maintained to provide an adequate degree of illumination in the event of failure of the normal electricity supply. Where emergency lighting is provided it shall be designed, installed and maintained in accordance with current Irish standards.