

17 February 2015

**ETCI announces the following Amendment No. 2.1 to the National Rules for Electrical Installations ET 101:2008 incorporating Amendment No.1:2011**

SWA sleeving

ETCI announces the following Amendment No. 2.1 to the National Rules for Electrical Installations ET 101:2008 incorporating Amendment No.1:2011, with retrospective effect from 1<sup>st</sup> September 2014.

**Amendment No. 2.1**

Clause 514.3.6 (b) is hereby amended as follows:

**Addition:** Notwithstanding this requirement, in SWA cables not having a protective conductor identified by the bi-colour green/yellow throughout its length, a conductor identified by the colour blue may be used as a protective conductor provided that its terminations have supplementary colour marking of green/yellow applied in accordance with 514.3.10.

**Ends.**



**ELECTRO-TECHNICAL COUNCIL OF IRELAND LIMITED  
2015**